

RESOLUTION NO. _____

WHEREAS, Potable Well No. 13 (Columbia Highway) has recently experienced a significant decrease in pumping capacity and other indications of mechanical failure which have made the well inoperable; and

WHEREAS, the city's current scheduled water well rehabilitation project has resulted in additional potable water wells out of service and the city is approaching increasing summer demands, thus requiring the immediate repair of Well No. 13; and

WHEREAS, Donald Smith Company Inc. (DSC) has submitted a quote in the amount of \$28,948.00 to pull the well, perform an evaluation and provide a report of repair needs; and

WHEREAS, DSC has performed this type of work for many years for the City of Dothan and is the only Alabama licensed well driller with the experience and capacity needed to perform repairs to the city's water production system.

NOW, THEREFORE, BE IT RESOLVED by the Board of Commissioners of the City of Dothan, Alabama, as follows:

Section 1. That based upon the recommendation of the Dothan Utilities Director, the City of Dothan issues an emergency purchase order to Donald Smith Company, Inc. of Headland, Alabama, in the amount of \$28,948.00 to remove the well unit, perform breakdown and inspection of the entire unit and provide a report of recommended repairs at Well No. 13.

Donald Smith Company, Inc.

746 East Main Street • Headland, Alabama 36345 • (334) 693-2969 • Fax (334) 693-3089

May 12, 2022

Mrs. Lindsay McDonald
Dothan Utilities
PO Box 2128
Dothan, Alabama 36302

RE: Well #13

Dear Mrs. McDonald:

After conducting a pump test today, we discovered a definite decrease in capacity. The pump test indicates a decrease of 150+ gallons per minute. Based on today's test and information provided of the most recent decreases, we recommend removal and inspection. Please review the following cost to remove and inspect Well #13:

- Crew to mobilize and remove unit.
- Breakdown and inspection of entire unit to determine causes of decrease in capacity.
- Provide report with our recommendations for rehabilitation of this pumping unit.
- Static well video inspection.


Total cost of removal and inspection-----\$28,948.00


We could start removal Monday or Tuesday if necessary.

If you have any questions concerning this proposal, please feel free to contact me at any time. We look forward to starting this project in the near future.

Respectfully,

DONALD SMITH COMPANY, INC


Matt Singletary
Pump Division



Water Wells • Pumps & Service • Utility Construction
Drilling Wells and Pumping Water Since 1946

BRANCH
P.O. Box 36
Shannon, MS 38868
Phone: (662) 767-9777
Fax: (662) 767-3107

Res. No. _____, issuing an emergency purchase order to Donald Smith Company, Inc. of Headland, Alabama, in the amount of \$28,948.00 to perform said emergency work at Well No. 13 (Columbia Highway), continued.

Section 2. That the sum of \$28,948 be appropriated in FY 2022 to the Utility Fund/Dothan Utilities-Water Department/Other Services & Charges/Maintenance Repair, Account Number 401-8215-582.30-36 for Well 13. This appropriation is to be funded by increasing the Utility Fund/Non-Revenue Resources/Utilization of Fund Balance, Account Number 401-0000-391.01-00 by the sum of \$28,948 in FY 2022.

Section 3. That Mark Saliba, Mayor of the City of Dothan and in such capacity, is hereby authorized and directed to sign said document for and in the name of the said city, which shall be attested by the City Clerk.

PASSED, ADOPTED AND APPROVED on _____

Mayor

ATTEST:

City Clerk

Associate Commissioner-District 1

Associate Commissioner-District 2

Associate Commissioner-District 3

Associate Commissioner-District 4

Associate Commissioner-District 5

Associate Commissioner-District 6
BOARD OF CITY COMMISSIONERS