



NOTES:

1. ASPHALT CONCRETE PAVEMENT JOINTS SHALL BE MECHANICALLY SAWED OR CUT WITH A PNEUMATIC CHISEL.
2. SURFACE TREATMENT PAVEMENT JOINT SHALL BE LAPPED AND FEATHERED.
3. SUBGRADE BASE TO BE COMPACTED 100% AASHTO T-99. TOP 8" BASE 95% AASHTO T-180.
4. DENSITY TEST REQUIRED PER PER FOOT OF FILL PER ROAD PROCESSING.
5. NO ROADWAY CUTS SHALL BE LEFT OPEN OVERNIGHT.

REPLACEMENT OF ROADWAY STRUCTURE

NOT TO SCALE

DETAIL NO: 04-104

REV. DATE: 10.3.19